

GOVERNMENT OF TELANGANA
ROADS AND BUILDINGS DEPARTMENT

From:
Smt B. Saritha M.Tech
Dy. Executive Engineer (R&B)

To,
Delhi Public School
Nadergul

Shamshabad Sub-Division.

Ranga Reddy District

Lr.No: DEE / SHBD / Building/Soundness/2023-24/

Dt: 10 -05-2023

Sir

Sub: (R&B) Dept-Delhi Public School,Nadergul - Structural Soundness
Certificate - Inspection Report - Submitted - Reg.

Ref: Endt.No : EE (R&B) /RRD/DB//HD/D2/2022-23/ 43

Dt . 8 .04.2022

With reference to the subject cited above, it is to submit that the Delhi Public School building located at Sy.Nos : 469/1 of Nadergul village in Balapur Mandal was inspected on 09.05.2023. The school is accommodated in the two buildings i.e 1) Main building which is G+3 floor and 2) The new building with Stilt + Ground + 4 Floors. These building belongs to M/s Balajee Arun Educational society as per the records submitted.

It is submitted that the buildings are constructed with RCC structure. According to the records submitted to this office, main building permission was accorded in the year 2008 for 3 floors and the new construction permission was accorded on 11.04.2018 up to 3 floors and permission for the fourth floor was obtained on 25-08-2020. The building construction completed in the year 2020. There are no structural drawings submitted to this office along with the letter and during inspection. Hence only superficial inspection of the building was done.

The Inspection was done superficially, and the details of the building as observed are mentioned below.

1. The Main school building is constructed with Ground + 3 Floors.
and new building is Stilt + Ground + 3 floors with provision for 4th floor .
2. Marble Flooring done in both the buildings.
3. Painting was done last three Year back..
4. No Dampness in the External and Internal Walls and Roof Slabs.

10



5. In the ground floor electrical wiring for the fans has to be concealed.

It is also submitted that Mr. S.G.S. Murthy, Vaarija Associates, Himayathnagar, Hyderabad, GHMC Certified Licenced Engineer has submitted the structural soundness certificate stating that the both the building are structurally safe and Soundness and followed the relevant IS Code standards and NBC 2005 during construction.

In this regard, based on the report from Mr. S.G.S. Murthy, Vaarija Constructions, the both building are superficially inspected and found to be fit for running the school for the period of One -year i.e 2023-24.

Moreover, the school management is completely responsible for taking of the periodical maintainance of the building regularly during this One-year period.

This is submitted for favour of taking further necessary action.

Yours faithfully

Santhos
10/05/2023
Dy. Executive Engineer (R&B)
Shamshabad Sub Division
Ranga Reddy

